

Branch Office : House No.-6, Sankardev Path, Pub-Sarania, Chandmari, Guwahati - 78 003 ASSAM

Ph. No. 09207035356 email : envision.pd2011@gmail.com

Recognized by Pollution Control Board, Assam.

STACK ANALYSIS REPORT

Date:	24/09/2013
Rep.No.	130924_14010036_02_001

Name & Address:

**M/s. GNRC INSTITUTE OF MEDICAL SCIENCE
(A Unit of GNRC Ltd.)**

**Sila Grant, Mouza-Sila
Senduri Ghopa
North Guwahati, Assam.**

Stack Description:

Stack attached to DG SET 500 KVA.

Date of Sampling: 20/09/2013

Date of Analysis: 21/09/2013

Sample Collected By: M/s. EEEPL

CODE	PARAMETERS	LIMITS	RESULTS
S ₁	Temperature of Flue Gas (° C)	-	143
S ₂	Average Flue Gas Velocity (m/sec)	-	5.04
S ₃	Total Particulate Matter (mg / Nm ³)	0.3	0.141
S ₄	NO _x (ppm)	9.2	1.72

Method of Analysis Followed: I.S. 11255, part I to IV

Opinion : All Parameters are within permissible limit

En-Vision Enviro Engineers Pvt. Ltd. Guwahati.



(Quality Control Manager)

End of Report

LAB/FM/04